4287A-07A

S E R V I C E N O T E

Supersedes: 4287A-07

4287A RF LCR Meter

Serial Numbers: JP1KG00000 to JP2KG99999, MY43100000 to MY43299999, MY43300413 to MY43300672 .

"PLL unlock" Error Message due to A3 Source Board Failure

Parts Required:

P/N	Description	Qty.
04287-69563	A3 Source Board	1
(or 04287-66563	A3 Source Board	1)

ADMINISTRATIVE INFORMATION

SERVICE NOTE CLASSIFICATION:					
MODIFICATION RECOMMENDED					
ACTION CATEGORY:	X ON SPECIFIED FAILURE [[]] AGREEABLE TIME	STANDARDS LABOR: 4.0 Hours			
LOCATION CATEGORY:	[[]] CUSTOMER INSTALLABLE [[]] ON-SITE X SERVICE CENTER [[]] CHANNEL PARTNER	SERVICE [[]] RETURN INVENTORY: X SCRAP [[]] SEE TEXT	USED X RETURN PARTS: [[]] SCRAP [[]] SEE TEXT		
AVAILABILITY: PRODUCT'S SUPPORT LIFE		NO CHARGE AVAILABLE UNTIL: July 2009			
AUTHOR: jm		PRODUCT LINE: WN			
ADDITIONAL INFORMATION:					

© AGILENT TECHNOLOGIES, INC. 2008 PRINTED IN U.S.A.



Page 2 of 2 4287A-07A

Situation:

There are some units among the indicated serials that are displayed "PLL unlock" error message because of A3 Source board failure. The failure is depending on the hours of operation.

Solution/Action:

When the error message is displayed, firstly check the output signal of A1 REF OSC referring the service manual. If the output signal of A1 is correct, A3 Source board is faulty. Replace the A3 Source board to 04287-69563 or 04287-66563.

New Part-Number Old Part-Number 04287-66563 04287-66553

or

04287-69563 04287-69553

Procedures:

Perform the post repair procedure referring the service manual.

Adjustments and Correction Constants (CC)

- A3 Local Level Adjustment
- A3 Output AGC Gain Adjustment
- A3 Output Level Adjustment
- A4 Local AGC Gain Adjustment
- A4 Local Level Adjustment
- A4 IF Local AGC Gain Adjustment

Verification

- "To Execute Internal Test" on page 117
- Frequency Accuracy Test
- Power Level Accuracy Test
- Impedance Measurement Accuracy Test

⁻ End of Document -